

EV100+LRX-E

Energy metering pressure independent control valve that optimizes, documents and proves water coil performance in chilled and hot water systems.

- Nominal voltage AC/DC 24 V
- Control modulating, communicative, Hybrid,
- Cloud
- Measures Energy
- Controls Power
- Manages Delta T






Structure

Components

The Belimo Energy Valve consists of a characterized control valve, an actuator and a thermal energy meter with a logic and a sensor module.

The logic module provides the power supply, the communication interface and the NFC connection of the energy meter. All relevant data are measured and recorded in the sensor module.

This modular design of the energy meter means that the logic module can remain in the system if the sensor module is replaced.



External temperature sensor T1 Integrated temperature sensor T2 Logic module 1 Sensor module 2 Characterized control valve with actuator 3

Technical data

Electrical data

Nominal voltage	AC/DC 24 V
Nominal voltage frequency	50/60 Hz
Nominal voltage range	AC 19.228.8 V / DC 21.628.8 V
Power consumption in operation	4 W
Transformer sizing	7 VA
Connection Ethernet	RJ45 socket
Power over Ethernet PoE	DC 3757 V
	11 W (PD13W)



®	Technical data sheet	EV100+LRX-E
Electrical data	Conductors, cables	AC/DC 24 V, cable length <100 m, no shielding or twisting required Shielded cables are recommended for supply via PoE
Data bus communication	Communicative control	BACnet IP, BACnet MS/TP Modbus TCP, Modbus RTU MP-Bus Cloud
Functional data	Valve size [mm]	1" [25]
	Operating range Y Operating range Y note	210 V 420 mA w/ ZG-R01 (500 Ω, 1/4 W resistor)
	Input impedance	100 kΩ (0.1 mA), 500 Ω VDC variable
	Operating modes optional	VDC Valiable

	Input impedance	100 kΩ (0.1 mA), 500 Ω		
	Operating modes optional	VDC variable		
	Position feedback U	210 V		
	Position feedback U variable	VDC variable		
	Running Time (Motor)	90 s		
	Control accuracy	±5%		
	Min. controllable flow	1% of V'nom		
	Fluid	chilled or hot water, up to 60% glycol max (open loop/steam not allowed)		
	Fluid Temp Range (water)	14250°F [-10120°C]		
	Close-off pressure ∆ps	200 psi		
	Differential Pressure Range	550 psi or 150 psi see flow reductions chart in tech doc		
	Flow characteristic	equal percentage or linear		
	Body Pressure Rating	360 psi		
	GPM	18.2		
	Servicing	maintenance-free		
	Manual override	external push button		
Measuring data	Measured values	Flow Temperature		
	Temperature sensor T1 / T2	Pt1000 - EN 60751, 2-wire technology, inseparably connected Cable length external sensor T1: 3 m		
Temperature measurement	Measuring accuracy temperature difference	±0.18 K @ ΔT = 10 K ±0.23 K @ ΔT = 20 K		
	Resolution	0.05°C		
	Remote Temperature Sensor Length	Standard: 9.8 ft. [3m]		
Flow measurement	Measuring accuracy flow	±2%*		
	Measurement Repeatability	±0.5% (Flow)		
	Sensor Technology	Ultrasonic with glycol and temperature compensation		
Safety data	Power source UL	Class 2 Supply		
	Degree of protection IEC/EN	IP54 IP54 when using protective cap or protective grommet for RJ45 socket. Sensor module: IP65		
	Degree of protection NEMA/UL	NEMA 1		
	Enclosure	UL Enclosure Type 1		
	Agency Listing	cULus acc. to UL60730-1A/-2-14, CAN/CSA E60730-1:02 CE acc. to 2014/30/EU and 2014/35/EU		
	Quality Standard	ISO 9001		
		1000 001		



EV100+LRX-E

Safety data	UL 2043 Compliant	Suitable for use in air plenums per Section 300.22(C) of the NEC and Section 602 of the IMC
	Ambient humidity	Max. 95% RH, non-condensing
	Ambient temperature	-22122°F [-3050°C]
	Storage temperature	-40176°F [-4080°C]
Materials	Valve body	Nickel-plated brass body
	Flow measuring pipe	brass body nickel-plated
	Stem	stainless steel
	Stem seal	EPDM (lubricated)
	Characterized disc	TEFZEL®
	Seat	PTFE
	Pipe connection	NPT
	O-ring	EPDM
	Ball	stainless steel

Safety notes



- This device has been designed for use in stationary heating, ventilation and air-conditioning systems and must not be used outside the specified field of application, especially in aircraft or in any other airborne means of transport.
- Outdoor application: only possible in case that no (sea) water, snow, ice, insolation or aggressive gases interfere directly with the actuator and that is ensured that the ambient conditions remain at any time within the thresholds according to the data sheet.
- Only authorized specialists may carry out installation. All applicable legal or institutional installation regulations must be complied during installation.
- The device contains electrical and electronic components and must not be disposed of as household refuse. All locally valid regulations and requirements must be observed.

Product features


Application	Water-side control of heating and cooling systems for AHUs and water coils.	
Operation	The Energy Valve is an energy metering pressure independent control valve that measures, documents and optimises water coil performance.	
Mode of operation	The HVAC performance device is comprised of four components: characterized control valve (CCV), measuring pipe with volumetric flow sensor, temperature sensors and the actuator itself. The adjusted maximum flow (V'max) is assigned to the maximum control signal DDC (typically 10 V / 100%). Alternatively, the control signal DDC can be assigned to the valve opening angle or to the power required on the heat exchanger (see power control). The HVAC performance device can be controlled via communicative or analogue signals. The fluid is detected by the sensor in the measuring pipe and is applied as the flow value. The measured value is balanced with the setpoint. The actuator corrects the deviation by changing the valve position. The angle of rotation α varies according to the differential pressure through the control element (see flow rate curves).	
Flow measurement	*All flow tolerances are at 68°F [20°C] & water.	
PoE (Power over Ethernet)	If necessary, the thermal energy meter can be supplied with power via the Ethernet cable. This function can be enabled via the Belimo Assistant App.	
	DC 24 V (max. 8 W) is available at wires 1 and 2 for power supply of external devices (e.g. actuator or active sensor).	
	Caution: PoE may only be enabled if an external device is connected to wires 1 and 2 or if wires 1 and 2 are insulated!	





Accessories						
5	Spare parts	Description		Туре		
		T-piece with thermowell DN 1/	/2" [15]	A-22PE-A09		
		T-piece with thermowell DN 3/		A-22PE-A10		
		T-piece with thermowell DN 1'		A-22PE-A11		
		T-piece with thermowell DN 1		A-22PE-A12		
		T-piece with thermowell DN 1		A-22PE-A13		
		T-piece with thermowell DN 2'		A-22PE-A14		
	Tools	Description	[]	Туре		
		Converter Bluetooth / NFC		ZIP-BT-NFC		
Electrical installation						
	-	Supply from isolating transfor	mor			
	$\mathbf{\Lambda}$	Supply from isolating transfor				
	/!\	Parallel connection of other ac	tuators possible. Observe	the performance data.		
		The wiring of the line for BACnet MS/TP / Modbus RTU is to be carried out in accordance with applicable RS485 regulations.				
		Modbus / BACnet: Supply and communication are not galvanically isolated. Connect earth signal of the devices with one another.				
				e connected to the thermal energy		
		Sensor connection: An additional sensor can optionally be connected to the thermal energy meter. This can be a passive resistance sensor Pt1000, Ni1000, NTC10k (10k2), an active sensor with output DC 010 V or a switching contact. Thus the analogue signal of the sensor can be easily digitised with the thermal energy meter and transferred to the corresponding bus				
		system.	سيبله وطفيت والموادين	nal anarmy matery This are be ashed		
		Analog output: An analog output is available on the thermal energy meter. This can be selected as DC 010 V, DC 0.510 V or DC 210 V. For example, the flow rate or the temperature of the temperature sensor T1 / T2 can be output as an analog value.				
Wire colors: 1 = black		Functions: 1 = Com				
2 = red		2 = AC/DC 24 V				
3 = white		3 = Sensor (optional)				
5 = orange		5 = 010 V, MP-Bus				
6 = pink		C1 = D - = A				
7 = grey		C1 = D = A C2 = D + = B				
Analog Control		BACne	t IP / Modbus TCP	PoE with BACnet IP / Modbus TCP		
ĪĪ						
Y DC (0)210 V						
U DC 210 V		l ~				
		± ~ 				
	Cable col	ors:				
Web-Browser	1 = black	GND		DC 24 V		
1 2 3 5 6 7	2 = red, A	C/DC 24 V	BACnet IP / Modbus TCP Web-Browser	PoE 11 W (PD 13W) BACnet IP / Modbus TCP Web-Browser		
	3 = white			$\dot{}$		
	5 = orang	e, DC 010 V, MP-Bus	3 5 6 7			
	6 = pink,	C1 = D- = A				
$C_1 C_2$	7 = grey,	C2 = D+ = B				
BACnet MS/TP / Modbus RTU						
GND +						
			Web-Browser			
	7					
	<u></u>					
	1 C ₂	[⊥] [→] C ₁ C ₂		$C_1 = D_{-} = A$		
AC/DC24V		AC/DC24V		$C_2 = D + = B$		




Connection with active sensor










Functions


Functions with specific parameters (Parametrisation necessary) MP-Bus, supply via 3-wire connection




A) additional MP-Bus nodes (max. 8)

M-Bus with converter in parallel

M-Bus with converter



MP-Bus via 2-wire connection, local power supply




M-Bus with converter in parallel mode with PoE with BACnet IP / Modbus TCP

A) additional MP-Bus nodes (max. 8)



Override control and limiting with DC 24 V with relay contacts (with conventional control or hybrid mode)



Installation notes


Recommended installation positions

The ball valve can be installed upright to horizontal. The ball valve may not be installed in a hanging position, i.e. with the stem pointing downwards.

1) Position control

2) Flow control

3) Power control




Installation position in return	Installation in the return is recommended.	
Water quality requirements	The water quality requirements specified in VDI 2035 must be adhered to. Belimo valves are regulating devices. For the valves to function correctly in the long term, they must be kept free from particle debris (e.g. welding beads during installation work). The installation of a suitable strainer is recommended.	
Servicing	Ball valves, rotary actuators and sensors are maintenance-free. Before any service work on the control element is carried out, it is essential to isolate the rotary actuator from the power supply (by unplugging the electrical cable if necessary). Any pumps in the part of the piping system concerned must also be switched off and the appropriate slide valves closed (allow all components to cool down first if necessary and always reduce the system pressure to ambient pressure level).	
	The system must not be returned to service until the ball valve and the rotary actuator have been correctly reassembled in accordance with the instructions and the pipeline has been refilled by professionally trained personnel.	
Flow direction	The direction of flow, specified by an arrow on the housing, is to be complied with, since otherwise the flow rate will be measured incorrectly.	
Cleaning of pipes	Before installing the thermal energy meter, the circuit must be thoroughly rinsed to remove impurities.	
Prevention of stresses	The energy meter must not be subjected to excessive stress caused by pipes or fittings.	




Inlet section

In order to achieve the specified measuring accuracy, a flow-calming section or inflow section in the direction of the flow is to be provided upstream from the flow sensor. Its dimensions should be at least 5x DN.



Dimensions

Туре



	7.6 16 [5.2 kg]				
Α	В	С	D	E	F
15.5" [394]	11.1" [282]	6.4" [163]	5.5" [140]	1.8" [46]	1.8" [46]