

#### Potable water valve, 2-way, Internal thread

- For potable water applications
- DVGW certified
- ACS certified
- WRAS certified
- Air-bubble tight








#### Type overview

Туре	DN
B2125PW-Q	32

### **Technical data**

Functional data	Valve size [mm]	1.25" [32]	
	Potable water certificate	NSF/ANSI 61	
		NSF/ANSI 372	
	Fluid	Potable water	
	Fluid temperature	-4.0212°F [-20100°C]	
	Close-off pressure ∆ps	230 psi	
	Differential pressure ∆pmax	25psi	
	Leakage rate	0%	
	Angle of rotation	90°	
	Pipe connection	Internal thread	
		NPT (female)	
	Installation orientation	upright to horizontal (in relation to the stem)	
	Servicing	maintenance-free	
	Cv	82	
Materials	Valve body	Lead free and dezincification resistant bronze (CW511L)	
	Stem	Lead free and dezincification resistant bronze (CW511L)	
	Seat	PTFE	
	O-ring	EPDM	
	Ball	Chrome plated lead free brass	


#### Safety notes



- The valve has been designed for use in stationary potable water systems and must not be used outside the specified field of application, especially in aircraft or in any other airborne means of transport.
- The valve does not contain any parts that can be replaced or repaired by the user.




Product features			
Operating mode	The on/off ball valve is adjusted by a rotary actuator. The rotary actuator is connected by an on/off signal. Open the ball valve counterclockwise and close it clockwise.		
installation notes			
Notes	The ball valve is a regulating device. To fulfil this control task in the long term, the circuit mus be kept free from particle debris (e.g. welding beads during installation work).		
Permissible installation orientation	The ball valve can be installed upright to horizontal. The ball valve may not be installed in a hanging position, i.e. with the stem pointing downwards.		
Servicing	Ball valves and rotary actuators are maintenance-free.		
	Before any service work on the control element is carried out, it is essential to isolate the rotary actuator from the power supply (by unplugging the electrical cable if necessary). Any pumps in the part of the piping system concerned must also be switched off and the appropriate slide valves closed (allow all components to cool down first if necessary and always reduce the system pressure to ambient pressure level). The system must not be returned to service until the ball valve and the rotary actuator have been correctly reassembled in accordance with the instructions and the pipeline has been refilled by professionally trained personnel.		
Flow direction	Please also ensure that the ball is in the correct position (marking on the shaft).		
	$\begin{array}{c} \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\$		
Dimensions			
<b>'ype</b> 32125PW-Q	DN         Weight           32         []		











# On/Off, Floating point, Non fail-safe, 24 V





## **Technical data**

Electrical data	Nominal voltage	AC/DC 24 V	
	Nominal voltage frequency	50/60 Hz	
	Nominal voltage range	AC 19.228.8 V / DC 21.628.8 V	
	Power consumption in operation	2.5 W	
	Power consumption in rest position	0.5 W	
	Transformer sizing	5.5 VA	
	Auxiliary switch	1x SPDT, 3 A resistive (0.5 A inductive) @ AC 250 V, adjustable 0100%	
	Switching capacity auxiliary switch	3 A resistive (0.5 A inductive) @ AC 250 V	
	Electrical Connection	18 GA plenum cable, 1 m, 3 m, or 5 m with 1/2" NPT conduit connector, degree of protection NEMA 2 / IP54	
	Overload Protection	electronic thoughout 090° rotation	
Functional data	Direction of motion motor	selectable with switch 0/1	
	Manual override	external push button	
	Angle of rotation	90°	
	Angle of rotation note	adjustable with mechanical stop	
	Running Time (Motor)	90 s / 90°	
	Running time motor variable	90 or 150 s	
	Noise level, motor	45 dB(A)	
	Position indication	Mechanical, pluggable	
Safety data	Power source UL	Class 2 Supply	
	Degree of protection IEC/EN	IP54	
	Degree of protection NEMA/UL	NEMA 2	
	Enclosure	UL Enclosure Type 2	
	Agency Listing	cULus acc. to UL60730-1A/-2-14, CAN/CSA E60730-1:02 CE acc. to 2014/30/EU and 2014/35/EU	
	Quality Standard	ISO 9001	
	UL 2043 Compliant	Suitable for use in air plenums per Section	
		300.22(C) of the NEC and Section 602 of the IMC	
	Ambient humidity	Max. 95% RH, non-condensing	
	Ambient temperature	-22122°F [-3050°C]	
	Storage temperature	-40176°F [-4080°C]	
	Servicing	maintenance-free	



Technical data sheet

ARX24-3-S

Technical data				
Weight	Weight	2.2 lb [1 kg]		
Materials	Housing material	Galvanized steel an	d plastic housing	
Fratester		0001/ Two actions 1 D. Constant Dollarities De		
Footnotes	†Rated Impulse Voltage 800V, Type action 1.B, Control Pollution Degree 3.			
Accessories				
Electrical accessories	Description		Туре	
	Battery backup system, for non-spring return models Battery, 12 V, 1.2 Ah (two required)		NSV24 US NSV-BAT	
Electrical installation				
<ul> <li>INSTALLATION NOTES</li> <li>Provide overload protection and disconnect as required.</li> <li>Actuators may be connected in parallel. Power consumption and input impedance must be observed.</li> <li>Actuators may also be powered by DC 24 V.</li> <li>Actuators Hot wire must be connected to the control board common. Only connect common to neg. (-) leg of control circuits. Terminal models (-T) have no-feedback.</li> <li>Actuators with plenum cable do not have numbers; use color codes instead.</li> <li>One built-in auxiliary switch (1x SPDT), for end position indication, interlock control, fan startup etc.</li> <li>Apply only AC line voltage or only UL-Class 2 voltage to the terminals of auxiliary switches. Mixed or combined operation of line voltage/safety extra low voltage is not allowed.</li> <li>Meets cULus requirements without the need of an electrical ground connection.</li> <li>Warning! Live electrical components!</li> <li>During installation, testing, servicing and troubleshooting of this product, it may be necessary to work with live electrical components. Have a qualified licensed electrician or other individual who has been properly trained in handling live electrical components perform these tasks. Failure to follow all electrical safety precautions when exposed to live electrical components could result in death or serious injury.</li> </ul>				
	(1) Common	loating Point 24 VAC Transformer	1     2     3     18       Blk (1)     Common       Red (2)     + Hot       Wht (3)     Y Input	



# **Electrical installation**

Wiring diagrams

